



SUPPLEMENTAL/BID BULLETIN

BULLETIN No. 01

Subject: PROCUREMENT OF SSF EQUIPMENT FOR NATURAL CRUMB RUBBER (SPR20) PROCESSING PLANT

This Bulletin No. 01 is hereby issued to address queries/clarifications raised by the prospective bidders in the recently conducted Pre-bid Conference last 23 October 2024:

Issues/Queries	Answers
1. Clarification regarding the specification requirement concerning to "PASSED" in relation to the NORDECO standards, as outlined in the Bid Data Sheet and Technical Specifications for the procurement of three (3) units of transformers.	To revise the specifications to the following: 3 Units Transformer <ul style="list-style-type: none">• 167 KVA Distribution Transformer 10*60 Hz• Primary Voltage 7620/13200 Volts• Voltage: 240/480 Volts inclusive of banking and testing fee• With Complete Accessories• Shall include electrical components based on Philippine Electrical Code standard: control panel board with pre wired components, motor control switches, magnetic contractors and overload relay, circuit protection and electrical supply line from the main control panel.• NORDECO Certification must be submitted upon delivery

For the information and guidance of all concerned.

28 October 2024, Davao City, Philippines


DEOLLY L. ROQUE
Chairperson, Bids and Awards Committee

REGION 11 (DAVAO REGION)

3F Mintrade Building, Monteverde corner Sales Sts.,
Davao City, Philippines, 8000

(082) 224-0511
www.dti.gov.ph
r11@dti.gov.ph