

Bid Bulletin No. 2

**“Supply, Delivery, Installation, and Commissioning of Machine (Generator Set) for the Bureau of Philippine Standards”
Bidding No. 21-045A**

December 7, 2021

This Bid Bulletin No. 1 is hereby issued to modify or amend the Bidding Documents.

Section VII: Technical Specifications

1-LOT Supply, Delivery, Installation And Commissioning of 200 kVa Generator Set

Engine:

- 1. Speed:** minimum 1800 rpm
- 9. Fuel-consumption:** minimum (38.6 L / hr) 100% load; minimum (29 L / hr) 75% load
- 14. OHSAS 18001, IEC 34, ISO 3046 and ISO 8528 compliant** – compliant to at least two (2)

Automatic Transfer Switch:

- NEMA 1 Breaker Type
- ATS will be installed inside the Electrical Room

Accessories:

34. DCEC Bag – **to delete**

- Please refer to the actual photo of the site via below link:

https://docs.google.com/presentation/d/1j59-paPFKkvn7tUUNjsaphz_NGxxAECc/edit?usp=sharing&oid=111140413817213515574&rtpof=true&sd=true

For the guidance and information of all concerned.

MARY JEAN T. PACHECO

Assistant Secretary
Chairperson, DTI Bids and Awards Committee



BIDS AND AWARDS COMMITTEE